



PUBLIC WORKS DEPARTMENT (B & R), HARYANA

Office of Executive Engineer,
Provincial Division,
PWD B&R Br., Faridabad.
Tele – 0129-2288187



pwd-eepd1-faridabad@hry.nic.in

Memo No. 5978

Dated 20/07/23

To

The Principal,
Northlan Educational Trust
PS-01, F-Block, Sector-88, Greater Faridabad

Subject:-

Building Safety Certificate of Northland Educational Trust Plot no. PS-01, F Block, Sector-88, Kheri road, Greater Faridabad.

Reference: -

Your letter No. NIS/C/2023/33 dated 19.06.2023.

In this connection of above cited subject, it is submitted that the above said school building is inspected by the Sub Divisional Engineer, Provincial Sub Division No.2, PWD B&R Br., Faridabad along with Sh. Virender Singh, Junior Engineer on 28.06.2023. The school building is having ground floor plus first floor. The inspection fee of site is deposited by the applicant vide GRN No. 0104376161 dated 26.06.2023. Following are the features of the building observed during the inspection of the school:-

GROUND FLOOR:-

➤

At ground floor there are 6 Nos Classroom, 01 No. Director Room, 1 No. Principal room, 01 No. Counsellor room, 01 No. Staff room, 01 No. reception Hall, 04 Nos. Washrooms for girls, 04 Nos. Washroom for boys, 03 Nos. Washroom for staff, 01 No. Washroom for Handicap, 01 No. Stair case exist in ground floor and 01 No. Lift exist in the building but not in working condition.

FIRST FLOOR:-

➤

AT ground floor there are 06 Nos Classroom, 01 No. Library, 01 No. Science Library, 01 No. Science Laboratory, 01 No. Computer Lab, 04 Nos. Washrooms for Girls, 04 Nos. Washroom for boy, 02 Nos. Washroom for Staff, 01 No. Stair Case exist in ground floor and 01 No. Lift exist in the building but not in working condition.

The building is constructed with frame structure having R.C.C column, beams slab and 9" thick load bearing outer walls, the structure stability certificate has been also enclosed, which has been issued by Rakesh Bhatia & Associates NIT Faridabad. The fire NOC has been issued to the valid for 2 years is attached herewith. The hygiene certificate has also been issued by office of Civil Surgeon Faridabad vide No. HHC/FBD/2023-23/78 dated 23.05.2023 and valid up to 31.03.2024 is attached with the case.

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate has been issued to the above mentioned school for the time period of three year. The periodical repair of the school building must be ensured.

DA/Nil

Executive Engineer
Provincial Division
PWD B&R Br. Faridabad

Executive Engineer,
Provincial Division,
PWD B&R Br., Faridabad

Endst.No.

Dated:-

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.2, PWD B&R Br., Faridabad for information and necessary with reference to his office Memo No. 1205 Dated:- 30.06.2023.

DA/Nil


Executive Engineer,
Provincial Division,
PWD B&R Br., Faridabad



ASSOCIATED ARCHITECTS

ENGINEERS, INTERIOR DESIGNERS & VALUERS

Office : Shop MCF No. B-187, Shiv Colony, Tigaon Road, Ballabgarh-121004, Faridabad (Haryana)

Resl. : H. No. 1649, Sector-2, Ballabgarh-121004, Faridabad (Haryana)

☎ : 09313382307
☎ : 09811553765
☎ : 08448849200

Ref. No.

AA/537/25

Date

19/4/2025

SAFETY CERTIFICATE

In pursuance of a request from, "NORTHLAND GLOBAL SCHOOL" situated at PS-01, Block-F, Sector-88, Faridabad Distt: - Faridabad (HRY.)

I have visited the site of "NORTHLAND GLOBAL SCHOOL" situated at PS-01, Block-F, Sector-88, Faridabad, Distt: - Faridabad (HRY.)

Belonging to "NORTHLAND EDUCATIONAL TRUST" on 19-04-2025 to verify the structural stability of the building and status of the structure.

I hereby certify that the Existing Ground floor + First Floor + Second Floor stood at the site with central passage & classrooms on both sides.

The building is a R.C.C. Frame structure resting upon R.C.C. columns & beams. All outer walls are 9" thick masonry wall, R.C.C. columns & beams.

The structural design has been checked & found to be in conformity with the N.C.B. & Indian standards code.

The school building as on today is structurally safe & sound.

Dharna Rani
19-04-2025
For Eng. Sign.

DHARNA RANI
BACHELOR OF TECHNOLOGY
(CIVIL ENGINEER)
Regn. No. 13, SECT-0281
H.No. 1649, Sec-2, Ballabgarh, FR